236 Cove Creek Lp.

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138070 PIN# 4636 12 9237.000 4636e01947 DATE Feb 16, 2007

OWNER OR APPLICANT Chesapeake Pointe LLC / Mark Benitez PHONE: Business _____ Home _____

ADDRESS 7360 Mt. Holmes Ferry Rd Smyrna, Ga. 30024

LOCATION Brawley Sch Rd - TR closed) Pines TR Cove Creek on left

SUBDIVISION Chesapeake Pointe BLOCK / SECTION 3 LOT 65/65A LOT AREA .69Ac + .42 Ac SITE CLASS. PSSFE DESIGN FLOW 480gpd L.T.A.R. .3 initial / .25 repair

Septic Tank: 1000 Gallons; STB 794 Date 11-11-14

Pump Tank: 1000 Gallons; PT 27 Date 11-24-14

Pump Make: Goulds Model WE05111HH Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1206 Linear Feet 402

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: pm 25% reduction

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons ____

☐ Business No. Employees ____

☐ Other _____

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:

Shave off any old burms in drainfield area.
1/22/15 Checked tanks & lines

Comments/Conditions:

Installed Quick 4 as drawn
3/23/15 Set 2 ft pressure manifold
Checked elect. & alarm

INITIAL SITE SKETCH

SEE PLAN from SAME

AS BUILT SKETCH

on 9-9-16

9-15-16: Pump line broken @ 5-6 points (lot on Farm Knoll Way building fence) Line replaced w/ ± 130 ft of 2" SCH-40 PVC [properly glued] 4-6' from PL.

- 100 L.F. of 2" SCH-40 PVC replaced for offsite for Lot 64-A.

- Tom Shuck

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit - not to exceed sixty months.

Signed: Warren A Nicholas date 7-27-07

Improvement Permit by: _____ date 2-16-07

Authorization to Construct by: _____ date _____

APPROVED APR 28 2014

Installed by: Richard Abernathy

Operation Permit by: Marian Dalton RS date 3/23/15

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK