10:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13763 / 15842 0 PIN# 4636 02 8703 DATE October 25, 2006

OWNER OR APPLICANT Chesapeake Pointe LLC Orleans Homes PHONE: Business 678-300-8521 Home

ADDRESS 7680 McEwen Ferry Rd, Suwanee GA 30024

LOCATION BSR TL Isle of Pines Rd TR Cove Creek Rd. on left

SUBDIVISION Chesapeake Pointe BLOCK / SECTION LOT 83 LOT AREA .69 Ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3 initial / .25 repair

Septic Tank: 1000 Gallons: STB 283 Date 2-3-10
Pump Tank: 1000 Gallons: PT 194 Date 3-11-10
Pump Make: Myers Model ME45 Serial No.
Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270
No Lines 4 Trench Width 24" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LP PPBPS
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other

Water Supply: ☐ Individual ☒ Public ☒ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:
Shave off any old burns in septic system area.

Comments:/Conditions: 9/22/09 Reviewed Floor plans, in compliance with Original plan MS

INITIAL SITE SKETCH

SEE PLAN from SPME

AS BUILT SKETCH

4/29/2010 Checked tanks, lines & set pressure (2ft)

The proposed / existing Deck w/ Roof & Patio addition does not appear to impact the existing septic system.
**NOTE: Shall be min. 5' from septic lines
see Site Plan
Andy Melville R.S.
Date: 9-18-12
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed date 12-12-06 Installed by: Willie Christenbury REHS

Improvement Permit by: date 10-25-06 Operation Permit by: date 6/28/2010

Authorization to Construct by: Andy Melville date 4-16-07 Existing System Inspection by: date

Maria Dobbins 9/25/09

HEALTH DEPT COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK