# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE October 27, 2006

PERMIT# 137632 PIN# 4686 02 9738

OWNER OR APPLICANT Chesapeake Pointe LLC / ORLEANS Builders PHONE: Business 678-300-8521 Home

ADDRESS 7380 McGinnis Ferry Rd. Suwanee, Ga. 30024 / 300 Foregate Point Circle Charlotte

LOCATION BSR 1 to Isle of Pines TR Coal Creek Rd. on left

SUBDIVISION Chesapeake Pointe BLOCK / SECTION 2 LOT 84 LOT AREA .69ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; ST8 794 Date 6-30-12

Pump Tank: ____ Gallons; PT ____ Date ____

Pump Make: ____ Model ____ Serial No. ____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: gravity 25% Reduction accepted

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☐ Individual ☒ Public ☒ Community

Gravel Depth N/A ☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:
Shave off any old burns in septic system area.

INITIAL SITE SKETCH

SEE Plan from S&ME

Comments:/Conditions: Installed Infiltrator Quick 4 Essentially as Shown Supply line installed deep through middle of lot

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date 12-12-06

Improvement Permit by: ____ date 10-27-06

Authorization to Construct by: ____ date 10/24/12

Installed by: Willie Christenbury RS date 2/12/13

Operation Permit by: ____ date ____

Existing System Inspection by ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK