IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lopez Trailer Park DATE 7-7-75 PERMIT NO. 152

PHONE: Business _____ Home _____

LOCATION OFF 1100

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 19 + 20 SECTION OR BLOCK NO. _____

House ( ) 2 Mobile Home (✓) Business ( ) Other _____

2 Mobile Home

No. Bedrooms 6 No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ¼ acre


Character & Porosity of Soil Sandy Clay loam Porosity Fair

Percolation Rate Not taken

Topography 2 to 5% Slope

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1100 Linear Ft. 400
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by E.T. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 7-7-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold