IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jesus Lopez DATE 8-12-74 PERMIT NO. 213

PHONE: Business _____ Home _____

LOCATION 150 West TL on 1109 TR on 1100 2½ mi on Right

S. R. No. _____

SUBDIVISION NAME Lopez Trailer Court LOT NO. 3 & 4 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (4) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (4)
Auto. Dishwasher	Yes ( )	No (4)
Auto. Wash. Machine	Yes (4)	No ( )
Site Suitable	Yes (4)	No ( )

Lot Area 10,000 Sq Ft

Character & Porosity of Soil Sandy Clay loam Loose
Percolation Rate 25 min/in
Topography 2% Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (4)

Installed by Ervin

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 8-13-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold