IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jesus Lopez DATE 12-16-05 PERMIT NO. 275

PHONE: Business _____ Home _____

LOCATION 1100 ¼ mi on right Past 1113 Jct.

S. R. No. _____

SUBDIVISION NAME Lopez Trailer Park LOT NO. 5+6 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other 2 mobile Homes

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil Clay loam (Porosity Fair)
Percolation Rate not taken
Topography 2 to 3 Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank [redacted] 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)
approved community water system.

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-16-05

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold