Dawn Richardson

4:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 125134 PIN# 4636 18 1696.001 4636-08-6377 DATE Feb 16, 06

OWNER OR APPLICANT Dockside Development / Zande Homes PHONE: Business 704-439-2029 Home

ADDRESS 17824 Statesville Rd. Cornelius N.C. 28031

LOCATION Brawley School Rd TR Blume Rd immediately on Beechtree ¼ mile ± TR chestnut Bony lane 1st lot on left 107 Chestnut

SUBDIVISION Beechtree Bay BLOCK / SECTION LOT 1/1A LOT AREA ≥30,000 ft² SITE CLASS PS SFE DESIGN FLOW 480gpd L.T.A.R. 3 initial / .25-.3 Repair

Septic Tank: 1000 Gallons: STB 312 Date 6-14-06

Pump Tank: 1000 Gallons: PT 250 Date 10-24-06

Pump Make: Myers Model ME50 Serial No.

Nitrification Field: No. fields 1 Square Feet 540 Linear Feet 270

No Lines X5 Trench Width 24" min 60c Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LPPPBPS on SFE 1A

Repair System Description: LPPPBPS on SFE 1A

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

7/31/06

Comments/Conditions: Re Revised Building plans & site plans; house proposed is larger than original permit however Septic system should still fit. Tanks may need to be closer to Beech Tree Rd; must be at least 5 ft from well

Comments/Conditions: Tanks Checked 11/29/06 Lines Checked & installed 12/21/06 Pressure, elect & alarm

INITIAL SITE SKETCH

1"=60'

AS BUILT SKETCH

The proposed / existing Inground Swimming Pool addition does not appear to impact the existing septic system.

**NOTE: Must keep Pool "cut" at least 15 ft from STs PT

Maria H. Dalton R.S.

Date: 10/3/12

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed Jason Clendinen for Dockside Development date 2-24-06

Improvement Permit by: Maria H. Dalton R.S. date 2-16-06

Authorization to Construct by: Maria H. Dalton R.S. date 7/31/06

Installed by: R&H R.S.

Operation Permit by: Maria H. Dalton R.S. date 2/7/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK