4:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 125134 PIN# 4636 18 1696.001 4636-08-6377 DATE Feb 16, 06

OWNER OR APPLICANT Dockside Development / Lande Hanes PHONE: Business 704-439-2029 Home

ADDRESS 17824 Statesville Rd, Cornelius N.C. 28031

LOCATION Brawley School Rd TR Blume TL immediately on Beechtree 1/4 mile ± TR chestnut Pony Lane 1ST LOT on left

SUBDIVISION Beechtree BAY BLOCK / SECTION LOT 1/1A LOT AREA 33,000 sq ft SITE CLASS. PS SEE DESIGN FLOW 480 gpd L.T.A.R. .3 mtd / .25-.3 Repair

Septic Tank: 1000 Gallons; ST8 312 Date 6-14-06
Pump Tank: 1000 Gallons; PT 237 Date 10-24-06
Pump Make: Myers Model ME50 Serial No.
Nitrification Field: No. Fields 1 Square Feet 540 Linear Feet 270
No Lines X5 Trench Width 24" min/36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LPPPBPS on SEE 1A
Repair System Description: LPPPBPS on SEE 1A
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth NA ☐ Gravity ☒ Pressure ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

7/31/06

Comments/Conditions: Revised Building plans & site plans; house proposed is larger than original permit however Septic System Shall still fit. Tanks may need to be closer to Beech Tree Rd; must be at least 50ft from well

Comments/Conditions: Tanks Checked 11/29/06
Lines Checked & installed 12/21/06
Pressure, float & alarm

INITIAL SITE SKETCH

1" = 60'

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed Jason Kendrick for Dockside Development date 2-24-06

Improvement Permit by: [signature] date 2-16-06

Authorization to Construct by: Maria H. Dotson RS date 7/31/06

Installed by: R & H date

Operation Permit by: Maria H. Dotson RS date 2/7/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK