DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RT Homes OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 5/26/94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: lot 52, North Shore
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS 4%	0-7	SAB - scl	1:1 fr			PS		.3
		7-32	SAB - c	1:1 fr-vfi					
		32-48	SAB - cl	1:1 fi					
2									
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE .3
EVALUATED BY: RHunsucker, RS OTHER(S) PRESENT: Paul Swearingen, Roger Sweezy
COMMENTS: Septic area (rear) is upslope from proposed dwelling & will require use of lift pump.