DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2623A84
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Robert Ingraham Homes OWNER: / AGENT: PHONE:
ADDRESS: 2900 B I-85 S. Service Rd. APPLICATION DATE: 10/27 DATE EVALUATED: 10/27/93
Charlotte, NC PROPOSED FACILITY: 4 bedroom SF Dwelling
Lot 3, North Shore PROPERTY SIZE: ~3/4 Ac.
LOCATION OF SITE: 1100 TL 1113 TR Cove Creek Rd. TR High Sail Ct. on left in Cul-D-Sac
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-12"	gr SL	1:1/fr	—	—	PS	—	.6
		12-32"	SAb C	1:1/fi	—	—	PS	—	.4
		32-48	SAb SiC	1:1/fi	—	—	PS	—	.35
2									
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35 gal/ft²/day
EVALUATED BY: B.R. Hinson OTHER(S) PRESENT: Rick Rumfeldt
COMMENTS: