IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

IREDELL COUNTY HEALTH DEPARTMENT - ENVIRONMENTAL HEALTH ☐ STATESVILLE OFFICE 704-878-5305 ☑ MOORESVILLE OFFICE 704-664-5281

PERMIT # REPAIR
OWNER SEAN DAVIS
SITE ADDRESS 111 WYNSWEPT
SITE DIRECTIONS RT. ISLE OF PINES, LOVE CREEK, WYNSWEPT
SUBDIVISION NORTH SHORE
PIN # 4636-10-7804
APPLICANT: SAME
OWNER / APPLICANT ADDRESS
PHONE: Home/Cell # 704-658-0998 Business #
DATE 9-12-12

Septic Tank Excess
Pump Tank
Pump Make
No. Nitrification Fields:
Trench Width
Comments / Conditions
Gallons: STB
Gallons: PT
Model
Max. Trench Depth 4 FT
Date
Date
Serial #
Lineal Feet
Max. Trench Bottom Depth
Gravel Depth

☐ New System ☑ Repair ☐ Expansion System Type I II III IV V VI
System Description:
Repair System Description: INSTALL DIST. BOX
Maintenance Agreement Required ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

LOT # 2 LOT AREA .633AC DESIGN FLOW 480 L.T.A.R. .3

☑ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/plumbing
No. Bedrooms 4
No. Persons
No. Employees
☑ Crawl Space ☐ Basement w/o plumbing
Water Supply: ☐ Private ☐ Public ☑ Community

INITIAL SITE SKETCH

OWNER SAID THERE WAS A LEAK IN HOUSE. ADVISED HER TO GET IT FIXED. INSTALLED NEW D-BOX TO REPLACE FLOW DIVIDER & OLD D-BOXES

LAKE

PROBED OUT DRAINFIELD BUT ONLY FOUND 400' OF GRAVEL. FROM ORIGINAL PERMIT SAYS 240

REPAIR

AS BUILT SKETCH

264'

80'

80'

80'

HOUSE

DRIVEWAY

260'

NEW D-BOX

EXISTING TANK

I hereby acknowledge receipt of this permit and agree to comply with all applicable laws governing the construction, operation and maintenance of the system. I understand that this permit may be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

IMPROVEMENT PERMIT with plat valid without expiration. ☑ IMPROVEMENT PERMIT with plat valid without expiration. Site plan valid 60 mo. ☑ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT—not to exceed 60 mo.

Applicant Signature: [signature]

IMPROVEMENT PERMIT by: REHS Date 9-12-12

AUTHORIZATION TO CONSTRUCT by: REHS Date 9-12-12

Installed by: LENTZ

OPERATION PERMIT by: [signature] REHS Date 9-12-12

Existing System Inspected by:

White Copy – Environmental H...

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION