IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 139705

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-11-4996

APPLICANT: PEACHTREE RES. PROP. APPLICANT ADDRESS: 516-D RIVER HWY MVILLE

SITE ADDRESS: 104 SANDY COVE CT. PHONE: 704-576-3887 ALT. PHONE:

SITE DIRECTIONS: BSR, ISLE OF PINES, COVE CREEK, SANDY COVE

SUBDIVISION: CHESAPEAKE POINT SECTION: 3 LOT # 55 LOT AREA: .71 ± .39AC SEE DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank 1000 (gal) STB 794 Date 3-7-14
Pump Tank 1000 (gal) PT 27 Date 3-7-14
Pump Make LIBERTY Model 280 Serial #
Nitrification Fields 1 # Lines 4 Linear Ft: 400'
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II (III)B IV V VI
System Description: PM 25% REDUCTION
Repair System Description: PANEL BLOCK
Maintenance Agreement Required: ☐ YES ☒ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions:

[redacted]

INITIAL SITE SKETCH

SEE APPROVED PLAN BY
MICHAEE ATHANAS
&
ASSOCIATES

- Installed as Drawn
- IQ4W Installed
(104, 104, 100, 96)

CHECKED BREAKERS
SET 2' PH BA 6-6-14

The proposed / existing Pool addition does not appear to impact the existing septic system.
**NOTE:

BA Ellis R.S.
Date: APPROVED MAY 2 2 2014
ICHD-Environmental Health Division

POOL MUST BE 15' FROM SEPTIC

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 2-10-14 Installed by: Richard Abernathy

IMPROVEMENT PERMIT by: BA Ellis Date: 1-23-14 OPERATION PERMIT by: Date: 6-6-14

AUTHORIZATION TO CONSTRUCT by: BA Ellis Date: 1-23-14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK