PARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Cresent Resources OWNER: ~ AGENT: __ PHONE: 663 6905
ADDRESS: PO Box 3002 APPLICATION DATE: 11-22-93 DATE EVALUATED: 11-22-93
Charlotte NC 28208 PROPOSED FACILITY: single family residence
PROPERTY SIZE: ____
LOCATION OF SITE: Phase III North Shore Subdivision lot 76
WATER SUPPLY: On-Site Well ____ Comm. Well ~ Public ____ Other ____ EVAL. METHOD: Auger Boring ~ Pit ____ Cut ____

C ON ADJACENT LOT

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-4	cl / mod gran	mfr	>42"	>42"	P	—	0.3
		4-28	c / mod sbk	mfi			P	—	0.3-.25
		28-42	sic / wk sbk	mfi			—	—	
		42+	sil saprolite						
2									
3									
4									
5									

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: 0.3-0.25
EVALUATED BY: A.L. OTHER(S) PRESENT: Tracy Jacobs
COMMENTS: Very rear of lot proposed site to pile dredge spoils