IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 138065

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636123253

APPLICANT: Peachtree Res. Prop. APPLICANT ADDRESS: Cove Creek Dr. Mooresville, NC 28117

SITE ADDRESS: 109 Sandy Cove Ct. Mooresville, NC PHONE: ALT. PHONE:

SITE DIRECTIONS: Brawley School School Rd TL Isle of Pines TR Cove Creek TL Sandy Cove on left

SUBDIVISION: Chesapeake Pt. SECTION: III LOT # 61 LOT AREA: .71 Ac DESIGN FLOW: 600gpd L.T.A.R.: .25

Septic Tank 1500 (gal) STB 383 Date 5-27-14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5 Linear Ft: 600
Trench Width 36" Max. Trench Bottom Depth 24" Gravel Depth N/A

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI
System Description: Gravity - 25% Reduction
Repair System Description: LPP PBPS
Maintenance Agreement Required: [ ] YES [ ] NO
[X] GRAVITY [ ] PRESSURE

[X] Residence No. Bedrooms 5
[ ] Business No. Persons 10
[ ] Other No. Employees
[ ] Slab [X] Crawl Space
[ ] Basement w/ plumbing [ ] Basement w/o plumbing

Water Supply: [ ] Private [ ] Public [X] Community

Comments / Conditions: This permit replaces previous permit dated 10-24-2006

INITIAL SITE SKETCH

See approved attached plan by Michael Athanas & Assoc. (dated 5-7-14)

AS BUILT SKETCH

INSTALLED AS SHOWN

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

[ ] **IMPROVEMENT PERMIT** *with plat valid without expiration.* [ ] **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* [X] **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date:

IMPROVEMENT PERMIT by: RS Date: 5/14/14

AUTHORIZATION TO CONSTRUCT by: RS Date: 5/14/14

Installed by: ABE-NAFTA 7-1-14

OPERATION PERMIT by: Date: 7-1-14

Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK