IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138064 PIN# 4636-12-4370.000 DATE October 24, 2006

OWNER OR APPLICANT Chesapeake Pointe, LLC PHONE: Business 678-300-8521 Home

ADDRESS 7380 McBurnes Ferry Rd. Suwanee, Ga. 30024

LOCATION

SUBDIVISION Chesapeake Pointe BSR TL Isle of Pines TR Cove Creek TL Sandy Cove on left at end

BLOCK / SECTION III LOT 60 LOT AREA .71Ac SITE CLASS. PS DESIGN FLOW 460gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 194 Date 5-19-14

Pump Tank: 1000 Gallons; PT 283 Date 5-19-14

Pump Make: Liberty Model EC50 Serial No.

Nitrification Field: No Fields Square Feet 1206 Linear Feet 402

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36"

[X] New System [ ] Repair [ ] Expansion System Type: I II (IIIB) IV V VI

System Description: pm 25% Reduction

Repair System Description: LPP PBBS

Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: [ ] Individual [X] Public [X] Community

Gravel Depth N/A [ ] Gravity [X] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments/Conditions:

Shave off old burms in septic system area.

Comments/Conditions: Quick 4 used, installed essentially as drawn

6/25/14 Checked tanks, lines & pressure

INITIAL SITE SKETCH

SEE PLAN from S&ME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: date 10-24-06

Authorization to Construct by: date 2/10/14

Installed by: Richard Abernathy

Operation Permit by: Richard Farris date 9/25/14

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK