IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 208732

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-12-5817

APPLICANT: TRUE HOMES APPLICANT ADDRESS: 2649 BREKONRIDGE CENTRA DR.

SITE ADDRESS: 109 FARM KNOLL WAY - Mooresville PHONE: 704-283-1229 ALT. PHONE:

SITE DIRECTIONS: RSR TL ISLE OF PINES, TR ROCK RIDGE POINT, TL FARM KNOLL, ON R

SUBDIVISION: ROCK RIDGE POINT SECTION: - LOT # 23 LOT AREA: .73 AC DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank 1500 (gal) STB Date

Pump Tank 1500 (gal) PT Date

Pump Make Goulds Model P51 Serial #

Nitrification Fields 1 # Lines 2 CENTER FED Linear Ft: 270'

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth -

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PANEL BLOCK

Repair System Description: SAME

Maintenance Agreement Required: ☑ YES ☐ NO

☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions:

INITIAL SITE SKETCH

SEE PLAN FROM KENNY OWENS

AS BUILT SKETCH

CHECKED TANKS & LINES BA 1-13-16

Set pressure, checked eleat & alarm. 2FT 1/27/16 MD

MAIN. CONTR. 2-15-16 BA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 10-5-15

IMPROVEMENT PERMIT by: APPROVED Date: SEP 25 2015

AUTHORIZATION TO CONSTRUCT by: APPROVED Date: SEP 25 2015

Installed by: SID GASKINS

OPERATION PERMIT by: Date: 2-15-16

Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

ROCKRIDGE POINT SUBDIVISION

APPROVED OCT 0 6 2015

RA

