IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 137635 PIN# 4636 13 1031 DATE October 27, 2006

OWNER OR APPLICANT Chesapeake Pointe LLC PHONE: Business 678-300-8521 Home

ADDRESS 7380 McGinnis Ferry Road, Suwanee, GA. 30024

LOCATION BSR TR Lake of Pines TR Cove Creek Rd. on left

SUBDIVISION Chesapeake Pointe BLOCK / SECTION 2 LOT 87 LOT AREA .74AC SITE CLASS. PS DESIGN FLOW 440gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 794 Date 7-7-08
Pump Tank: 1000 Gallons; PT 27 Date 6-17-08
Pump Make: Myers Model ME50-11 Serial No.
Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270
No Lines 3 Trench Width 24" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LD PPBPS
Repair System Description: LD PPBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☒ Public ☒ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:
Shave off any old burms in septic system area.

Comments/Conditions: 9/18/08 Okay to end feed 3 lines Drilled 5/32" hole, set 2PT head Checked tanks & lines 10/7/08 & pressure

INITIAL SITE SKETCH

SEE PLAN from S&ME

AS BUILT SKETCH

2/19/09 Electro Alarm Checked

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: Johnson, RS date 10-27-06

Authorization to Construct by: date 6-11-08

Installed by: Willie Christenbury

Operation Permit by: date 3/18/09

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK