IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 137636 PIN# 4636 13 2009 DATE October 27, 2006

OWNER OR APPLICANT Chesapeake Pointe LLC PHONE: Business 678-300-8521 Home

ADDRESS 7380 McGinnis Ferry Rd Suwanee, GA. 30024

LOCATION BSL Rt side of lines Rt Cove Creek Rd. on left 330

SUBDIVISION Chesapeake Pointe BLOCK / SECTION 2 LOT 88 LOT AREA .98Ac SITE CLASS. PS DESIGN FLOW 450gpd L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 794 Date 12-5-07

Pump Tank: 1000 Gallons; PT 271 Date 7-13-08

Pump Make: Myers Model ME50511 Serial No.

Nitrification Field: No Fields Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: pm 25% Reduction

Repair System Description: LPPBBS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:

Shave off any old burns in septic field area.

Comments:/Conditions:

Installed EZ Flow as Drawn 2/2/09 Checked tanks, lines & set 2" pressure

INITIAL SITE SKETCH

SEE Plan from SAME

AS BUILT SKETCH

2/19/09 Checked elect. & alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 12-12-06

Improvement Permit by: date 10-27-06

Authorization to Construct by: date 6-11-08

Installed by: Willie Christen by RS

Operation Permit by: date 2/20/09

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK