DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Chesapeake Point — APPLICATION DATE
ADDRESS: — DATE EVALUATED: 5/16/05
PROPOSED FACILITY: — PROPOSED DESIGN FLOW (.1949): — PROPERTY SIZE:
LOCATION OF SITE: Lot 94 — PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut — TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 0-2%	0-25	SBK C	SS SP SE FR	Red, F, F mica				.3
		25-48	WK/MO SBK CL	SS SP SE FR	Red; C mica/Sap ↳ F Y Br Relic				
2	Linear 0-2%	0-2	MO GR SL	SS SP SE FR	Red				.3
		2-34	SBK C	SS SP SE FR	Red, F/C Sap, F Yel Br Relic				
		34-48	SL SAP MA	SS SP FR SE	Yel Br				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Kathleen Hauser
OTHER(S) PRESENT:

COMMENTS: