Old # 133712

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 208747

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-13-8299

APPLICANT: True Homes APPLICANT ADDRESS: 2649 Breton Ridge Central Dr.

SITE ADDRESS: 130 Farm Knoll Way - Mooresville PHONE: 704-283-1229 ALT. PHONE:

SITE DIRECTIONS: RSR, TL Isle of Pines, TR Rock Ridge Point, TR Farm Knoll, on R

SUBDIVISION: Rock Ridge Point SECTION: - LOT # 40 LOT AREA: .169AC DESIGN FLOW: 480 L.T.A.R.: .25

Septic Tank	1500 (gal)	STB	Date	☑ New System	☐ Repair	☐ Expansion	System Type: I II III ⓘ V VI
Pump Tank	1500 (gal)	PT	Date	System Description:	LP - Panel Block		
Pump Make		Model	Serial #	Repair System Description:	Same		
# Nitrification Fields	1	# Lines	4	Linear Ft:	338'		
Trench Width	24"	Max. Trench Bottom Depth	36"	Maintenance Agreement Required:	☑ YES	☐ NO	
				Gravel Depth	—	☐ GRAVITY	☑ PRESSURE

☑ Residence	No. Bedrooms	4	Water Supply	
☐ Business	No. Persons		☐ Private	
☐ Other	No. Employees		☐ Public	
☐ Slab	☑ Crawl Space		☑ Community	
☐ Basement w/plumbing			☐ Basement w/o plumbing	

Comments / Conditions: Plastic Infiltrator tank
BA Checked tanks 2/4/16

2/12/16 Checked drain lines MD
90, 80, 92, 92 lines

INITIAL SITE SKETCH

SEE PLAN FROM KENNY OWENS

AS BUILT SKETCH

2-29-16
Alarm OK Pressure Transducer used C1546-7B-05
conduit requires sealing

3-3-16 Conduit sealed [electrical mastic/putty]
Lot 21

	Date	Initials
Drain Lines Checked	2/12/16	MD
Tanks Checked	2/4/16	BA
Pressure Manifold or Valve Box Checked		
Pressure Head Set	2-29-16	
Electrical Checked	3-3-16	
Floats Set	3-3-16	
Alarm Checked	3-3-16	
Maintenance Contract Y / N		

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 10-5-15 Installed by: Sid Gaskins

IMPROVEMENT PERMIT by: APPROVED Date: SEP 25 2015 OPERATION PERMIT by: Jason Shuck Date: 3-3-16

AUTHORIZATION TO CONSTRUCT by: APPROVED Date: SEP 25 2015 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

ROCKRIDGE POINT SUBDIVISION

