IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 208744

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-13-9874

APPLICANT: TRUE HOMES APPLICANT ADDRESS: 2649 BRECKONRIDGE CENTRA DR.

SITE ADDRESS: 152 FARM KNOLL WAY - Mooresville PHONE: 704-283-122 ALT. PHONE:

SITE DIRECTIONS: RSR, ISLE OF PINES, TR ROCK RIDGE, TR FARM KNOLL, ON R

SUBDIVISION: ROCK RIDGE POINT SECTION: LOT # 35 LOT AREA: .81AC DESIGN FLOW: 480 L.T.A.R.: .3 (.125R)

Septic Tank 1500 (gal) STB Date

Pump Tank 1500 (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 6 Linear Ft: 311'

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth —

☑ New System ☐ Repair ☐ Expansion System Type: I II III ⓘ V VI

System Description: LP - PANEL BLOCK

Repair System Description: PRE TREATED DRIP

Maintenance Agreement Required: ☑ YES ☐ NO

☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions:

INITIAL SITE SKETCH

SEE PLAN FROM KENNY OWENS

AS BUILT SKETCH

TANKS CHECKED 11-24-15 BA

CHECKED LINES, SET 3' PH 2-2-16 BA

MAIN. CONTR. 2-15-16

CHECKED ELEC. BOX 2-25-16

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Cody Rudell Date: 2-2-16 Installed by: SID GASKINS

IMPROVEMENT PERMIT by: APPROVED Date: JAN 25 2016 OPERATION PERMIT by: Date: 2-25-16

AUTHORIZATION TO CONSTRUCT by: APPROVED Date: JAN 25 2016 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

ROCKRIDGE POINT SUBDIVISION

Plat 60 Page 73

APPROVED JAN 2 5 2016

BA

