IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 132302 176303 PIN# ~~4636443600~~ 4636142597 DATE Nov. 16, 05

OWNER OR APPLICANT Chesapeake Pointe, LLC / Orleans Homes PHONE: Business _____ Home _____

ADDRESS 7380 McGinnis Ferry Rd. Suwanee GA. 30024

LOCATION Crawley Set Rd. / TR Isle of Pines TR Cove Creek Rd.

SUBDIVISION Chesapeake PH I BLOCK / SECTION _____ LOT 8 LOT AREA 1.63Ac SITE CLASS. 05 DESIGN FLOW 480gpd L.T.A.R. _____

Septic Tank: 1000 Gallons: STB 794 Date 3-5-13

Pump Tank: 1000 Gallons: PT 27 Date 3-18-13

Pump Make: Hydromatic Model SHEF45 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270

No Lines 3(CF) Trench Width 24" min 8'oc Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: 4 BBBS

Repair System Description: 4 BBBS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 4 No. Persons _____ No. Employees _____

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Certified site evaluation and system design performed by Kit Wilcox and Kathleen Haven of S&ME.

INITIAL SITE SKETCH

SEE Plan from S&ME

Comments:/Conditions: 12/12/12 Reviewed Floor Plans & Site plans in Compliance with original permit Installed 3 lines @ 90 ft ea.

AS BUILT SKETCH

4/10/13 Checked Tanks

4/11/13 Checked 1st line 3/16" hole at head

4/12/13 Checked 2 & 3 line & set pressure

5-16-13 CHECKED EL. & ALARM MAINTENANCE ATTACHED

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Randy Safford date 11-21-05 Installed by: Willie Christenbury

Improvement Permit by: _____ date 11-16-05 Operation Permit by: _____ date 5-16-13

Authorization to Construct by: _____ date 12/2/12 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK