IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 132305 PIN# 4636 14 6492 DATE Nov 16, 05

OWNER OR APPLICANT Chesapeake PP. LLC / Orleans PHONE: Business _____ Home _____

ADDRESS 7380 McGinnis Ferry Rd. Suwanee Ga

LOCATION Beverly Shores PL Isle of Palms TR Cove Creek Rd. on left

SUBDIVISION Chesapeake PP BLOCK / SECTION 1 LOT 98 LOT AREA .85 Ac SITE CLASS. RS DESIGN FLOW 480 gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 794 Date 3-25-13
Pump Tank: 1000 Gallons; PT 283 Date 11-23-05
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 640 Linear Feet 320
No Lines 4 Trench Width 24"min 36" Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI
System Description: LPPPBPS
Repair System Description: LPPPBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons _____ No. Employees _____

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Digital site evaluation and system design performed by Rob Wilcox and Kathleen Haver of SAME

INITIAL SITE SKETCH

8/27/13 Reviewed Revised Floor plans, in compliance with original plan

SEE Plan from SAME

Comments:/Conditions: 7/29/13 Reviewed Floor plans & Site in Compliance with Original plan Floor plans only show 3 Bedrooms but Septic is sized for 4 Bedrooms

AS BUILT SKETCH

Note: House slightly longer than original House box but should still fit.

3/16" Hole

INSTALLED AS SHOWN

SET 2' PH

CHECKED LINES & TANKS

- Electrical checked ACP 1-7-14
- Maintenance Contract Received ACP 1-7-14

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: David Ingold date 11-21-05

Improvement Permit by: _____ date 11-16-05

Authorization to Construct by: _____ date 7/29/13

Installed by: WILLIE CHRISTENBURY

Operation Permit by: _____ date 1-8-14

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK