IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 | Mooresville Office (704) 660-3625

BA

Old # 133702

PERMIT # 208743

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

✓ PIN # 4636147082

APPLICANT: True Homes

APPLICANT ADDRESS: 2649 Brekonridge Center Dr Monroe, NC

✓ SITE ADDRESS: 156 Farm Knoll Way - Mooresville, NC PHONE: 704 283-1229 ALT. PHONE:

SITE DIRECTIONS: Brawley School Rd TR Isle of Pines TR Rockridge PL

✓ SUBDIVISION: Rock Ridge Pt. SECTION: LOT # 33 LOT AREA: 1.80 Acre DESIGN FLOW: 480 gpd L.T.A.R.: .3

Septic Tank	1500* (gal)	STB 2111	Date 4-15-16	☒ New System	☐ Repair	☐ Expansion	System Type: I II ◯III IV V VI	☒ Residence	No. Bedrooms 4
Pump Tank	(gal)	PT	Date	System Description: 25% Reduction - Gravity				☐ Business	No. Persons 8
Pump Make	Model		Serial #	Repair System Description: LPPPBPS				☐ Other	No. Employees
# Nitrification Fields 1	# Lines 4		Linear Ft: 400'	Maintenance Agreement Required:	☐ YES	☒ NO		☐ Slab	☒ Crawl Space
Trench Width 36"	Max. Trench Bottom Depth 36"		Gravel Depth N/A	☒ GRAVITY	☐ PRESSURE			☐ Basement w/plumbing	☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions: * Specified in Septic plan

INITIAL SITE SKETCH

See attached / approved plan by Septic Environmental Solutions (dated 2/5/16, approved 2/23/16)

AS BUILT SKETCH

7-8-16: Gamble Septic Tanks 1500-gal top seam tank w/ a Polylok PL-68 Filter

	Date	Initials
Drain Lines Checked	7-11-16	BA
Tanks Checked filter not installed	7-8-16	BA
Pressure Manifold or Valve Box Checked		BA
Pressure Head Set		BA
Electrical Checked		
Floats Set		
Alarm Checked		
Maintenance Contract Y / N		
Comments:		

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date: 3-3-16 Installed by: Sid Gaskins

IMPROVEMENT PERMIT by: Maria Dotson RS Date: 2/23/16 OPERATION PERMIT by: BA Date: 7-11-16

AUTHORIZATION TO CONSTRUCT by: Maria Dotson RS Date: 2/23/16 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

ROCKRIDGE POINT SUBDIVISION

