DELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

130

PERMIT# 141356 PIN# 4636 14 9680 .101 DATE April 17, 2007

OWNER OR APPLICANT Chesapeake Pointe, LLC PHONE: Business _____ Home _____

ADDRESS 7380 McGinnis Ferry Rd. Suwanee, GA. 30024

LOCATION TR Core Creek 1st building lot on left Newby Sch Rd. TR Lake of Pines

SUBDIVISION Chesapeake Pointe BLOCK / SECTION 1 LOT 101 LOT AREA 2.4 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 312 Date 6-20-08

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth _____

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: gravity 25% Reduction accepted

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons _____ No. Employees _____

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions:

Existing Well must be properly abandoned and verified prior to the issuance of an Authorization to Construct. Well abandonment permit issued 9/3/08

Comments:/Conditions:

INITIAL SITE SKETCH

Well Abandonment GW30 Received 9/12/08

AS BUILT SKETCH

Installed EZ Flow 30 135 as shown

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Karen Dinsmore

Improvement Permit by: _____ date 7-27-07 Installed by: Willie Christenbury

Authorization to Construct by: _____ date 4-17-07 Operation Permit by: _____ date 9/18/08

_____ date 4/17/08 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK