IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Pg 9 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTIO

PERMIT# 130163 / 17806 PIN# 4636 15 4033 DATE August 8, 05

OWNER OR CONTRACTOR Chesapeake Pointe, LLC / Orleans Homes PHONE: Business _____ Home _____

ADDRESS 7380 McEwen's Ferry Rd, Sumner, Gen. 30024

LOCATION Brawley Sch Rd. TL Isle of Pines TR Cove Creek TR Kipjak Pt. on left

SUBDIVISION Chesapeake Pointe BLOCK / SECTION _____ LOT 5 LOT AREA 1.32ac SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; STB 794 Date 7/25/13 ☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

Pump Tank: 1000 Gallons; PT 283 Date 7/25/13 System Description: LP PBPS

Pump Make: Hydromatic Model SHEF5 Serial No. _____ Repair System Description: LP PBPS

Nitrification Field: No Fields 1 Square Feet 540/810 Linear Feet 270 Maintenance Agreement Required: ☒ Yes ☐ No

No Lines 2@135'(CF) Trench Width 24" min 8'oc Max Trench Bottom Depth 36" Gravel Depth NA

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms ____ No. Employees ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: OR 36" MAX 9'oc

Site Evaluation and Layout performed by S&ME

INITIAL SITE SKETCH

5.4 1/2 5.4 1/2 5.6a 5.5 3/4

SEE plan by Paul Pennington and Rob Willeg of S&ME

Comments:/Conditions: Floor plans in Compliance with original plan. Plan only shows 3 Bedrooms, but still wants 4 Bedrooms

AS BUILT SKETCH

End Fed lines 2 @ 135ft ea

9/7/13 Checked tanks & lines & set 2ft pressure

10/16/13 Checked effl. & alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 8/10/05 Installed by: Willie Christianbury

Improvement Permit by: _____ date 8-8-05 Operation Permit by: _____ date 10/16/13

Authorization to Construct by: _____ RS date 4/3/13 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK