IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Ta. d MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# ~~130 TBL~~ 201245 PIN# 4636 15 5233 DATE August 8, 05

OWNER OR CONTRACTOR Chesapeake Pointe, LLC / Orleans Homes PHONE: Business _____ Home _____

ADDRESS 7380 McGinnis Ferry Rd Suwanee, Ga 30024

LOCATION Brawley Sch Rd. to Isle of Pines TR Cove Creek TR Skipjack Pt. at end

SUBDIVISION Chesapeake Pointe BLOCK/SECTION _____ LOT 4 LOT AREA .93 SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 794 Date 3-25-14

Pump Tank: 1000 Gallons; PT 27 Date 3-10-14

Pump Make: Myers Model ME45 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 540/810 Linear Feet 270

No Lines 3@90' Trench Width 24" min/36" max Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: @ 36" max 90 c

Site Evaluation & Layout performed by S+ME

INITIAL SITE SKETCH

SEE plan by Paul Pennington & Rob Willcox of S+ME

Comments:/Conditions: * 5/32 Holes, * lines checked, Tanks, + 2' pressure head set AZP 5-6-14

6/27/14 Elect & alarm checked MD

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 8/10/05

Improvement Permit by: _____ date 8-8-05

Authorization to Construct by: _____ date 1-14-14

Installed by: TD Lowe Grading

Operation Permit by: _____ date 6/27/14

Existing System Inspection by: _____ date _____

COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK