IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 315.00 Pg. 9 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTIO.

PERMIT# 130189 17262 PIN# 4636 15 7089 DATE August 8, 05

OWNER OR CONTRACTOR Chesapeake Pointe LLC / Orleans Homes PHONE: Business _____ Home _____

ADDRESS 7380 McGinnis Ferry Rd., Suwanee, Ga. 30024

LOCATION Brawley Sch Rd. TL dble d Pener TR Cove Creek TR Skipjack Point on the right

SUBDIVISION Chesapeake Pointe BLOCK / SECTION _____ LOT 2 LOT AREA .86Ac SITE CLASS P5 DESIGN FLOW 450gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; STB 794 Date 6-13-12

Pump Tank: 1000 Gallons; PT 27 Date 11-20-11

Pump Make Hydromatic Model SHEF45 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 540/810 Linear Feet 270

No Lines 3@90'CF Trench Width 24" @ 6' min Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees _____

☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: @ 36" 90'C max

"Shove off" old burrow in Septic system area (initial & repair)

Site Evaluated & Layout performed by S&ME

INITIAL SITE SKETCH

SEE plan by Paul Pennington and Rob Willcox of S & ME

Skipjack Pl

Comments:/Conditions: 3/8/2012 Reviewed Floor plans, in compliance with T.P. 3/16" hole drilled

AS BUILT SKETCH

PL 251.75

House

STB

PL 324.52

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 8-10-05 Installed by: Willie Christianbury

Improvement Permit by: _____ date 8-8-05 Operation Permit by: _____ date 9/4/12

Authorization to Construct by: _____ date 3/8/2012 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK