DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ron Smith APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 1-16-03
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 27 Whispering Pines PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4-6%	0-7	gr brn sil	frssp					.3
		7-38	mfsbk RC	frsp					
		38-60	wkfsbk R-yrcl	frsssp	common mi fsspp				
2	4-6%	0-6	gr brn sil	frssp					.3
		6-31	mfsbk RC	frsp					
		31-60	wkfsbk yrcl	frsssp	few mi fspp				
3		0-4	gr brn sil	frssp					.3
		4-10	gr wksbk R brn sil	frssp					
		10-32	mfsbk RC	frsp sosp					
		32-60	m-wkfsbk yrcl	frsssp	few common mi fspp				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gen 25% bed	Gen 25% bed
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DM
OTHER(S) PRESENT: _____

COMMENTS: _____