4636184811

IREDELL COUNTY HEALTH DEPARTMENT

12803 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C W Brewer DATE 12/17/91 PERMIT NO. 2L-9-A-3

PHONE: Business _____ Home 663-4669

LOCATION Springfield Subdivision, Beech Tree Rd (1234) TR int. Springfield to third lot on L S. R. No. 1234

SUBDIVISION NAME Springfield LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil P / c-trans. clay
Percolation Rate 4
Topography 2%
Depth to Water Table 24"
Rock or other impervious formations None observed

Lot Area 20,000 FT²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5 @ 60' x 3'
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: OK'd to change drainfield to conventional trenches. Trenches no deeper than 36".

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 9/17/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold