4636185703

10138

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C.W. Brewer DATE Nov. 1, '89 PERMIT NO. 24-9-A-2

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 (Blume) immediately TR 1234 (Beechtree) ~¼ mile TR Meadow Creek Lane 2nd lot on left S. R. No. _____

SUBDIVISION NAME Springfield LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	

Character & Porosity of Soil clay

Percolation Rate 2.35


Topography 6-8%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

Lot Area .461 AC.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1020 Linear Ft. 340

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACL

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. Hanson, RS DATE 11-1-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold