DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CW Brewer OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: Jan 6, 94
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: ~6.4 AC
LOCATION OF SITE: Lot 19 Springfield Meadow Lake Lane
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-17"	gr-SAB/CL	1:1/ fr S/sticky	—	—	PS	—	.4
		17-36	SAB/C	1:1/ fr S/S/sticky	—	—	PS	—	.35
		36-48	wk SAB/SiCL	1:1/ slight S/sticky	—	—	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: OK Hunsucker OTHER(S) PRESENT:
COMMENTS: