IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 208348

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-22-1837.000

APPLICANT: True Hughes APPLICANT ADDRESS: 2649 Brekonridge Center Dr. Monroe NC

SITE ADDRESS: 119 Wheaton Ln. Mooresville NC PHONE: ALT. PHONE:

SITE DIRECTIONS: R-32, TL Isle of Pines, TR Rockridge Point, TL Wheaton Ln., Site on L

SUBDIVISION: Rockridge Point SECTION: LOT # 4 LOT AREA: .690 DESIGN FLOW: 600 GPD L.T.A.R.: .25

Septic Tank 1500 (gal) STB 744 Date 4-20-15
Pump Tank 1500 (gal) PT 477 Date 4-20-15
Pump Make Model Serial #
Nitrification Fields 1 # Lines 6 Linear Ft: 400'
Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LP PPBPS
Repair System Description: Same
Maintenance Agreement Required: ☒ YES ☐ NO ☐ GRAVITY ☒ PRESSURE

☒ Residence ☐ Business ☐ Other ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing
No. Bedrooms 5 No. Persons 10 No. Employees

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions: Maintain All Septic Rules.

INITIAL SITE SKETCH

See Attached Approved Design From Septic Environmental Solutions

Date APPROVED MAR 13 2015

AS BUILT SKETCH

Checked Lines, Tanks, Set 3' PH BA



PE51M
SUBMERSIBLE PUMP
.5HP 1/60/115 9.5MA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 3-16-15 Installed by: Sid Gaskins APPROVED Date: JUN 02 2015

IMPROVEMENT PERMIT by: APPROVED MAR 13 2015 OPERATION PERMIT by:

AUTHORIZATION TO CONSTRUCT by: APPROVED Date: MAR 13 2015 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

ROCKRIDGE POINT SUBDIVISION

