IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 | Mooresville Office (704) 660-3625

Old # 133752

PERMIT # 208721

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-22-7522.000

APPLICANT: True Homes | APPLICANT ADDRESS: 2649 Brickyard Crossing Dr Monroe NC

SITE ADDRESS: 125 Wheaton Ln. Mooresville NC | PHONE: | ALT. PHONE:

SITE DIRECTIONS: 150 to 5th on Pines, to Rockford Point, to Wheaton Ln.

SUBDIVISION: Rock Ridge Point | SECTION: | LOT # 6 | LOT AREA: 1 Acre | DESIGN FLOW: 600 GPD | L.T.A.R.: .3

Septic Tank	1500 (gal)	STB	338	Date	11-30-15	☒ New System	☐ Repair	☐ Expansion	System Type: I II III IV V VI
Pump Tank	1500 (gal)	PT	411	Date	11-23-15	System Description: LPP - PDPS			
Pump Make		Model		Serial #		Repair System Description: LPP - PDPS			
# Nitrification Fields	1	# Lines	5	Linear Ft:	335'	Maintenance Agreement Required:	☒ YES	☐ NO	
Trench Width	24"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A		☐ GRAVITY	☒ PRESSURE	

☒ Residence	No. Bedrooms	5	Water Supply
☐ Business	No. Persons	16	☐ Private
☐ Other	No. Employees		☐ Public
☐ Slab	☒ Crawl Space		☒ Community
☐ Basement w/plumbing	☐ Basement w/o plumbing		

Comments / Conditions: Maintain at least 50' from any well.

1/6/16 Checked tanks & lowest lines
1/7/16 Checked remaining drainlines

INITIAL SITE SKETCH

See Attached Approved Design By Septic Environmental Solutions Dated 9/25/15

AS BUILT SKETCH

1/27/16 Checked 2ft pressure, elect. & alarm

2-15-16 MAIN. CONTR. ATTACHED

3A

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date: 10/8/15 Installed by: Sid Gaskins

IMPROVEMENT PERMIT by: [signature] Date: 9/25/15 OPERATION PERMIT by: 3A Date: 2-15-16

AUTHORIZATION TO CONSTRUCT by: [signature] Date: 9/25/15 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

ROCKRIDGE POINT SUBDIVISION

