2.00 4636230265 2019889 4.30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 133714 PIN# ~~4636 23 3131.042 4636230265~~ DATE March 24, 06

OWNER OR APPLICANT Dignet Enterprises PHONE: Business 704 309 0123 Home

ADDRESS 2125 Hargrove Rd Charlotte N.C. 28211

LOCATION Brawley Sch Rd. TR Isle of Pines TR Rocky Farm Rd. 4th lot on Right

SUBDIVISION Rocky Ridge PH BLOCK / SECTION LOT 42/42A LOT AREA .69AC+SFE SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .25 initial (Required) 12-25-05 Repair

Septic Tank: X 1500 Gallons; STB 334 Date 3/17/13	☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI	☒ House/Mod. Home No. Bedrooms 4	Water Supply: ☐ Individual
Pump Tank: X 1500 Gallons; PT 477 Date 3/11/13	System Description: LPPPBPS	☐ Mobile Home No. Persons	☒ Public
Pump Make: Model Serial No.	Repair System Description: LPPPBPS on SFE 42A	☐ Business No. Employees	☒ Community
Nitrification Field: No Fields 1 Square Feet 640 Linear Feet 320	Maintenance Agreement Required: ☒ Yes ☐ No	☐ Other	
No Lines 7 Trench Width 24" min 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure	☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing		

Comments/Conditions: * PER Plan Specs. Shave off old burnts in initial and repair septic areas.

Comments/Conditions: 5.8 4.11 4.8 4.7 4.2 3.9 5.1 - 5/32" hole installed

INITIAL SITE SKETCH

SEE PLAN from State

AS BUILT SKETCH

4/19/13
+ LINES CHECKED
+ TANKS CHECKED
- WELL IN CONSTRUCTION

INSTALLED AS PER PLAN

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Robert B. Stegel date 4/11/06

Improvement Permit by: D. Hinson, RS date 3-24-06

Authorization to Construct by: Judy Whitley REHS date 3-7-13

Installed by: Chris Stevens

Operation Permit by: C. [signature] date 5/17/13

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK