IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

APP# 133715 / 176942 PIN# 4636233131.043 4636231296

OWNER OR APPLICANT Grand Cypress Investment Inc. Homes PHONE: Business 704.309.0123 Home

ADDRESS 2125 Stinson Ferry Rd Charlotte NC 28211

LOCATION Brawley School Rd. N side of Lines TR Rocky Farm Rd. 3rd Lot on Right

SUBDIVISION Rocky Ridge BLOCK / SECTION LOT 43 DATE March 21, 06

Septic Tank: 1500 * Gallons: STB 444 Date 3-11-13

Pump Tank: 1500 * Gallons: PT 444 Date 3-8-13

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270

No Lines 3 CF Trench Width 24" min Bloc Max Trench Bottom Depth 36"

LOT AREA 1.76 Ac SITE CLASS. BS DESIGN FLOW 480gpd L.T.A.R. .3

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

Gravel Depth NA ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: * Per Plan Specs
Well must be properly Abandoned prior to issuance of Auth to Construct / Abandonment documentation required.
Shave off any old burms in septic system area.

Comments:/Conditions: Well abandoned 2/5/13 Info. attached
2/6/13 Reviewed Floor plans; in compliance with original permit

INITIAL SITE SKETCH

SEE Plan from SAME

AS BUILT SKETCH

CHECKED TANKS LINES & VALVE Box 4-16-13
SET PM/ELEC/ALARM 5-17-13
MAINTENANCE ATTACHED

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ ☒ Improvement Permit with site plan valid for sixty months

Signed: Robert B. Stevens

Improvement Permit by: date 4/11/06

Authorization to Construct by: date 3-21-06

HEALTH date 2/6/13

Installed by: STEVENS SEPTIC

Operation Permit by: RA-000 date

Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months