Lot 8 Villages at Isle of Pines Fast Track Septic System Information

Number of Bedrooms	3
Basement or Crawl	crawl space
Design Flow (gpd)	360
LTAR (gpd/ft2)	0.25
Primary System Type	LP PPBPS
No. Lines	1 @ 70' endfed 1 @ 80' centerfed 1 @ 100' centerfed
Total Ft. Line	250
Pump Required	yes
Distribution Device	valve box with LPP dist.
Maintenance Agreement Required	yes
Repair System Type	LP PPBPS
Total Ft. Line	256
Pump Required	yes
Elevations (rod readings)	
Upper Line	white 6'11"
Lower Line	red 12'10"
Tank	14'
House Corner	left rear 8'9"
Reference Pt.	angle pt on left PL 7'7"

Notes: tanks could possibly be relocated to left side of house

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bonanza Dev. APPLICANT: Village of Isle Pines
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: Houses PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Lot 8

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 5-10% R-R	0-21	wsbk sl	fr ss/so	F-c 4/1 bc	50+	S-1 40+		PS .25
		21-40	mabk/sbk c	fr s/c					
		40-50	wsbk cl	fr ss/so					
2	L 5-10% L-R	0-17	wsbk sl	fr ss/so	F-c 4/1 bc	42+	S-1 32+		PS .25
		17-36	mabk/sbk c	fr s/c					
		36-42	wsbk cl	fr ss/so					
3	7-22-05 8% L	0-19	wk sbk sl/ls	fr ss/so	few gravel throughout, few in/so				.00
		19-52	abk rc/cl	fr ss/so/sp					
4	1% L	0-36	abk rc	fr ss/so/sp	few gravel throughout				.3
		36-48	m-wk sbk rc/cl	fr ss/so/sp					
		48-55	wk sbk L	fr ss/so/sp	common so/sp				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: PCP