DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bonanza Dev. Lot 9 APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Lot 9

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4/2 ~52	0-7	gr lm scl	fr ss/so	c shp, mott/grey color 7-48	48"			PS .25 (2)
		7-18	wsbk R c	fr ss/so					
		18-48	wsbk mott cl	fr ss/so					
2	L ~52	0-24	wsbk sl/c	fr ss/so	F mott lr c mott c ~24 35"				LPP ? .1
		24-48	wsbk/ c	fr s/p					
			plty / lbc						
3	T-cc ~52	0-19	gr/wsbk sl/sbk	fr ss/so	F mott br	45"			PS .25
		19-29	wsbk sc	fr ss/so					
		29-45	m sbk c	fr s/p					
4	L ~52	0-11	gr/wsbk scl	fr ss/so	br red c mott (br) red	f 35 c mott			PS .25 .35 35"
		11-30	msbk/sbk c	fr s/p					
		30-50	msbk m	fr ss/so					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: [illegible] Dev. Lot 3 APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Lot 9

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
5	L ~5%	0-6	WSBK cl	fr ss/po	rich br				PS .25
		6-27	msbk/abk c	fr s/p	red - few yellow, yellow and red mixed				-3> 25"
		27-54	WSBK cl	fr ss/po					
6 NW	L ~5%	0-9	WSBK scl	fr ss/po					LPD .1
		9-42	WSBK c	fr s/p	red br, few fine distinct				PS .3 > 42"
		42-45	WSBK cl	fr ss/p					
7 3	L 2-4% 45%	0-10	wk sbk vfsl	fr ss/p	common gleyed matrix				.225-.25
		10-34	ABK RC	fr-fi ss/p					
		34-51	WKSBK yRCl	fr ss/p					
4		0-25	wk sbk scl	fr s/p	com gley/brown/red				.25-.25
		25-45	wk sbkc	fr s/p					
		45-60	wk sbk cl	fr ss/po		60			.30-.30

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____