DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bonanza Dev Co. OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 10/24/95
PROPOSED FACILITY: ___
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 17, Mallard Cove phase 3
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 0-8%	0-15	gr-wksbk Rdsy sl/cl	fr					.3
		15-36	mssbk RC	fr s.p.					
		36-48	m-wksbk RCL	fr L ss.p.					
2 10/26/95 AK	LSS 26%	0-10	gr-brwsl	fr					.3
		10-36	ssbk RC	fr s.p.					
		36-48	m-wksbk RCL	fr ss.p.					
3 Repeat Hydra #3	L 10%	0-9	gr brwsl	fr l.p.					.37
		9-30	sbk RC	fr sp l.p.					
		30-48	sbk RCL	fr ss.p.					
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: ___ OTHER(S) PRESENT: ___
COMMENTS: 10/26/95 LP PPBPS w/ Mike Hearn.
3/13/96 Revisited site; best trenches indicate .37 gpd/sq ft would be acceptable. Approx 900' lateral total. At this time dark indicated likely would likely go w/ 600' chambered w/ 3/4" rock spacing.