DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ron Smith APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 1-16-03
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 28 Whispering Pines PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-5	wkSBK compacted fr sil	frssp					.3
		5-10	compacted wkMABK RC	fi sp					710"
		10-46	mfsbk yel	frsssp sbw					
2	4-6%	0-4	wkSBK RlinCL	frsssp					.3
		4-17	wkSBK RC	frssp					
		17-41	wkSBK yx cl	frsssp					
3		0-11	gr fsa scl	frsssp					.3
		11-52	wkmk fsabk RC Mottles	frsp-sssp few vfirmsp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	95	95
System Type(s)	Gen 25% Red	Gen LP 35% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DMH
OTHER(S) PRESENT: _____

COMMENTS: _____