DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dienst — APPLICANT: ___
ADDRESS: ___ — APPLICATION DATE: ___ — DATE EVALUATED: 7-16-04
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): ~~4 Bdrm~~ 3 — PROPERTY SIZE: ___
LOCATION OF SITE: Lot 2 The Preserve — PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut — ~~Need another pit~~
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	#1 TC	0-12	wk fsbk vfr scl	fr sss p					.3
		12-28	m fsbk RC	fr sss p					
		28-48	w f sbk RSCL	fr sss p	common in sap				
2	#2A TC	0-10	wk fsbk brn scl	fr sss p					.3
		10-21	m fsbk RC	fr sss p					
		21-31	wk fsbk R scl	fr sss p	few common in sap				
		31-50	massive R LSap	fr sss p					
3		0-5	gr brn scl	fr sss p					.3
		5-22	m fsbk R c	fr sss p	SAP				
		22-34	w f sbk vfr cl	fr sss p	common in sap				
		34-51	massive pale R sl sap	fr sss p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	SFRW 25%	Sand Mound 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: [signature]