I-SITE WASTEWATER SECTION

COUNTY: _____

# SOIL/SITE EVALUATION
## for ON-SITE WASTEWATER SYSTEM

ER: Dirst Ent. APPLICANT: _____

DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7-16-04

OPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____

CATION OF SITE: Lot 4 The Preserve PROPERTY RECORDED: _____

ATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____

ALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut

PE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

| .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|
| ① | 0-12 | wkfsbkyrscl | fr sssp | | | | | .3 |
| | 12-34 | wkfsbk rbrnscl | fr sssp | | | | | |
| | 34-53 | wkfsbk rsc | fr sssp | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| #4 TCS 10% ↓ | 0-12 | wkfsbk brnscl | fr sssp | | | | | .3 |
| | 12-25 | mfsbk msc | fr sssp | saprol mixed sap | | | | |
| | 25-50 | [illegible] L sap | fr NS-SS | NP-sp | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | 0-10 | gr. brnl sl | fr sssp | | | | | .25-.3 |
| | 10-31 | mfsbk rc | fr sssp | sap | | | | |
| | 31-51 | wkfsbk rbrn sc | fi sssp | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| ilable Space (.1945) | PS | PS |
| em Type(s) | Conv 25% Red | Conv 25% Red |
| LTAR | .25-.3 | .25-.3 |

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): PS

EVALUATED BY: _____

OTHER(S) PRESENT: Paul Brannigan