IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

...TATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

PERMIT# 128265 PIN# 4636 33 3208.000 4636320757 DATE 5/13/05

OWNER OR CONTRACTOR Bonanza Development / Scott Needham PHONE: Business 704-363-9942 Home

ADDRESS 816-G Brawley Sch. Rd, Mooresville, NC. 28117

LOCATION 1100 TL Lake on Pins on (L) ~ 400' before Turnbuckle Rd.

SUBDIVISION Village of Lake of the Pines BLOCK / SECTION LOT 2.5 LOT AREA 30,000 FT² SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .25

Septic Tank: 1000✓ Gallons; STB 794 Date 12/23/05

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1080 Linear Feet 360

No Lines 3@120' Trench Width 3' Max Trench Bottom Depth 3' Gravel Depth

X New System ☐ Repair System Type: I II III IV V VI

System Description: GRAVITY → 25% R-Duction

Repair System Description: LP → 16" PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

X House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 3

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☒ Community Heater Utilities

Comments:/Conditions: Fast Track

See Attached Plan on 1:50 scale by Paul Pennington

INITIAL SITE SKETCH

See Attached Drawing

Comments:/Conditions: Infiltrator installed Installed as shown on site plan.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Bonanza Development by Scott R. Needham date 5/17/05

Improvement Permit by: Wesley Sparks R.S. date 5/13/05

Authorization to Construct by: Wesley Sparks RS date 5/13/05

Installed by: F J Ervin

Operation Permit by: Wesley Sparks R.S. date 1/27/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK