DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dewst APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7-22-04
PROPOSED FACILITY: STR PROPOSED DESIGN FLOW (.1949): 450gpd PROPERTY SIZE: _____
LOCATION OF SITE: lot 39 The Preserve PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Very thick vegetation - once cleared up maybe 25% reduction initial w/ pond repair

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Op 0-4% ES	0-9	gr-wksbk brnsl	frssso					.3
		9-19	mfsbk RC	fr sp SSP					
		19-44	wkfsbk gpcl	frssso	few mot sap				
2	0-4% S	0-9	wksbk brnsl	frssso					.3
		9-44	mfsbk RC	fr-fr SSSP SSP					
				few fine mot sap 40%					
3		0-9	gr-wksbk brnsl	frssso					.3
		9-22	mfsbk RC	fr-sp-SSSO SSP					
		22-52	wkfsbk RCL	fi-frssso	few mot sap				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	RS	RS
System Type(s)	LPP	LPP
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: _____
OTHER(S) PRESENT: Paul Pennington