Paid $75.00 Statesville

RECEIVED SEP 23 2013 DN



MICHAEL ATHANAS & ASSOCIATES
LICENSED SOIL SCIENTIST
1999 CANDLEWICK DRIVE
FORT MILL, S.C. 29715
803-802-4403 (office)
803-802-4402 (fax)

Reference: Data Sheet for 105 Estate View Court, Lot 28, The Cove at Chesapeake Point SD
House Footprint: Refer to Plat
Water Source: Community Water
Number of Bedrooms: 3/360gpd
Pre-Determined LTAR: Initial 0.25 gpd/ft2 Initial & .3 Repair (ICHD)
Suggested System Type: Initial LP PPBPS., Repair LP PPBPS
Distribution: CVB
Septic/ Pump tank size: 1000gal

Line	Actual Length	Design Length	Elevation
Pink 1	**Initial/Existing**		
Blue 2	**Initial/Existing**		
White 3	**Initial/Existing**		
Orange 4	**Initial/Existing**		
Red 5	**Initial/Existing**		
Pink 6	97'		
White 7	73'		
Blue 8	64'		
Orange 9	60		

Initial/Existing System: 320' of 25% Reduction
Septic Tank: 1000gal

Repair System: LP PPBPS, 294

Comments: This lot is currently permitted for a four bedroom panel block system @.25 LTAR by ICHD. MA&A has re-established a new repair area in order to accommodate a pool area. Pink1-Red5 is the installed initial system and lines Pink6-Orange9 are the proposed repair lines, 294 linear feet. Please note MA&A excavated two additional soil observations to verify the soils rating determined by ICHD. If there are any questions, please feel free to contact us.