DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dienst — APPLICANT: ____
ADDRESS: ____ — APPLICATION DATE: ____ — DATE EVALUATED: 7-28-04
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480 gpd — PROPERTY SIZE: ____
LOCATION OF SITE: Lot 28 The Preserve — PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFIL CLASS & LTAI
1		0-9	gr wk sbk brn sl	fr ss sp					
		9-53	wk fsbk yR sc	fr s sp ss sp few gy brn mottles few gravelly roots					.25
2	≤ 15%	0-9	gr brn sl	fr ss sp					
		9-34	mk fsbk R C	fr ss sp ss sp					
		34-48	wk fsbk yR cl	fr ss sp common mi sp	mdg w. rock				.3
3		0-6	wk fsbk brn sl	fr ss sp					
		6-27	mk fsbk R C	fr ss sp ss sp					.3
		27-48	wk fsbk yR cl	fr ss sp common mi sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPPPBPS	LPPPBPS
Site LTAR	.125 (side from lot 27)	.13 (Web-Urena)

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH
OTHER(S) PRESENT: Paul Brannigan