DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Barnes Dev Co- Lot 14A - 05-14 APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: house PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
SEPTIC AREA BEHIND LOT 24

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 5-10Z	0-6	WSBK SL	FR 10YR 4/6	BR				PS .3
		6-21	MSBK C	FR 5Y 5/6	RED				
		21-51	WSBK CL	FR 5Y 5/8	MOTTLED	LINED SAND			
2	L 5-10Z	0-23	MSBK C	FR 5Y 5/6	RED				PS .3
		23-51	WSBK CL	FR 5Y 5/8	MOTTLED	LINED SAND			
3	L 5-10Z	0-6	GR SCL	FR 10YR 5/6	BR				PS .3
		6-18	MSBK C	FR 5Y 5/6	RED				
		18-48	WSBK CL	FR 5Y 5/8	MOTTLED	LINED	SAPROLITE		
4	6-29-05 8% L	0-21	SBK RC	FRSP-SSSP SEAL					.3
		21-55	WKSBK RCL	FRSSSP CONTINUOUS MIX SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____