IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 20312

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-33-5409

APPLICANT: Bonanza Dev. Co. APPLICANT ADDRESS: 816-G Brawley Sch Rd Mooresville NC

PHONE: 704-662-0105 ALT. PHONE: 704-363-9942

SITE ADDRESS: 119 Vista View Pl - Mrsvl.

SITE DIRECTIONS: Brawley Sch Rd, TL on Isle of Pines, TL on Meadow Crest, TL on East Vista View Pl, Lot at end on L

SUBDIVISION: The Villages at Isle of Pines SECTION: — LOT # 15 LOT AREA: 0.69 DESIGN FLOW: 360 gpd L.T.A.R.: 0.3

Septic Tank	1000	(gal)	STB	794	Date	9-14-16	☑ New System	☐ Repair	☐ Expansion	System Type: I II III (IV) V VI	☑ Residence	No. Bedrooms	3	Water Supply			
Pump Tank	1000	(gal)	PT	27	Date	8-22-16	System Description:			LP PPBPS	☐ Business	No. Persons	6	☐ Private			
Pump Make	Liberty		Model	250HV-5	Serial #		Repair System Description:			LP PPBPS	☐ Other	No. Employees		☐ Public			
# Nitrification Fields	1		# Lines	3	Linear Ft:	210	Maintenance Agreement Required:	☑ YES	☐ NO		☐ Slab	☑ Crawl Space		☑ Community			
Trench Width	24" min		Max. Trench Bottom Depth	36"	Gravel Depth	N/A		☐ GRAVITY	☑ PRESSURE		☐ Basement w/plumbing			☐ Basement w/o plumbing			

Comments / Conditions: CVB should be @ or above highest initial septic line

Tanks 18ft From House

11/30/15 Renewed Floor Plans, in Compliance with Septic plan

10/19/16 Check Drainlines & tanks

INITIAL SITE SKETCH

SEE DESIGN BY SAME

(This Permit Replaces Septic Permit Dated 6-20-05)

(New Design Dated 6-5-14 Approved 6-18-14)

AS BUILT SKETCH

	Date	Initials
Drain Lines Checked	10/19/16	MD
Tanks Checked	10/19/16	MD
Pressure Manifold or Valve Box Checked	12-16	BA
Pressure Head Set		BA
Electrical Checked		BA
Floats Set		BA
Alarm Checked		BA
Maintenance Contract (Y) N	12/8/16	MD

Attached

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

☐ IMPROVEMENT PERMIT with plat valid without expiration. ☐ IMPROVEMENT PERMIT with site plan valid for 60 mos. ☐ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Applicant Signature: Scott R. Needham Date: 7/21/14

PERMIT by: Date: 6-18-14

CONSTRUCT by: Maria Dotson RS Date: 11/30/15

Installed by: Date: 12-16-16

OPERATION PERMIT by: Date:

Existing System Inspected by:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

SECTION
- SECTION
GUTTER SECTION

LOT 15

SCALE: 1" = 50'

Lot 27 is smc
Lot 28 is well lot, lo

