IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 102824 PIN# 4636 34 6464 DATE 10/21/06

OWNER OR APPLICANT Wm Skeen/William O'Connell PHONE: Business 704-574-0767 Home

ADDRESS 259 Pintail Ln. Mooresville, NC. 28117

LOCATION 1100 TL Stutts Rd. TR FAIRWAY DR. ON (L) OFF Cul DE SAC

SUBDIVISION FAIRWAY ESTATES BOOK / SECTION LOT 224 LOT AREA .61 SITE CLASS. P3 DESIGN FLOW 360 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 760 Date 1-14-12

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1080 Linear Feet 360

No Lines 4 Trench Width 3' Max Trench Bottom Depth 24" 20"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: ULTRA SHALLOW 1-25% RED.

Repair System Description: SHALLOW LPP ON LOT 225

Maintenance Agreement Required: ☐ Yes ☒ No

Gravel Depth NA ☒ Gravity ☐ P

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other


No. Bedrooms 3 No. Persons No. Employees


Water Supply: ☐ Individual ☐ Public ☐ Community NEW

☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions:

INITIAL SITE SKETCH





(1) FARM DRAIN COULD BE EXTRA DEEP FOOTING DRAIN FOR HOUSE.

(2) ONLY CHANGE POSSIBLE WOULD BE TO DECREASE HOUSE SIZE.

(3) 30" TRENCH DEPTH - SUITABLE COVER WILL BE REQUIRED TO REACH 12" COVER UNIFORMLY PLACED

11-21-20+19-17

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X [illegible] date 10-30-06

Improvement Permit by: Wesley Sparks RS date 10/21/06

Authorization to Construct by: Wesley Sparks RS. date 10/21/06

Reissued by Marian Dobson 2/27/12

Installed by: A-1 Backhoe

Operation Permit by: BAlley date 7-17-12

Existing System Inspection by: date

HEALTH DEPT COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

SL1 FAIRWAY DR.