IREDELL COUNTY HEALTH DEPARTMENT

COMPLAINT FORM

Date 12-13-06

Name of Complainant Scott Ward

Address 166 Fairway Telephone 779-4277

Complaint House next to lot he's building on has failing Septic running out into the road.

Persons Responsible for Complaint

Address 160 Fairway Dr Telephone N/A

Detail Directions to Complaint Sewage running out into Fairway Dr Lot 228?

Road No.

Referred to Date

Action*

Date

Final Disposition

Date

Signed

*Use Back If Needed.

Send Copy of Permit

Owner: Jacinto Yaines

Phillip Lewis - Attorney for Builder

(704) 716 0905

Patrick Joseph
Associates
HOMES OF DISTINCTION

Fairway Drive Water Evaluation

Meter Readings	
April 17, 2007	23,160
May 17, 2007	41,580

- 31 days between readings
- Water usage over 31 days is 18,420 gallons
- Average daily water usage = 594 gallons
- Current usage capacity is 120 gallons per day per bedroom for 3 bedroom home = 360 gallons per day